



U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 162.029/202/0

Expires: 30 July 2014

FIXED FIRE EXTINGUISHING SYSTEM

FIREBOY-XINTEX, INC
0-379 LAKE MICHIGAN DRIVE NW
GRAND RAPIDS MI 49544

Fireboy Models CG2-025-227 through CG2-1000-227 pre-engineered fire extinguishing systems.

Maximum protected volume is 25 cu. ft. through 1000 cu. ft. (0.71 cu. m. through 28.3 cu. m.). Approved for installation in unmanned engine compartments on recreational boats and certain other uninspected vessels. To be installed in accordance with manufacturer's instruction manual. Equipped with automatic actuation only. See approved instruction manual for details.

Identifying Data: FM Report 3004865, dated September 29, 1999 and manufacturer's Instruction Manual 18004, dated May 6, 2009, Rev. E.

Follow-up Program: FM

Approval valid only for products from above manufacturing location.

Models CG2-50-227 through CG2-1000-227 previously approved under, and may be marked with separate approval Nos. 162.029/203/0 through 162.029/214/0.

Supersedes and extends certificate 162.029/202/0 dated May 30, 2005, and consolidates all Model CG2-227 units under one approval number.

*** END ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.



GIVEN UNDER MY HAND THIS 30th DAY OF
JULY 2009, AT WASHINGTON D.C.

K. J. HEINZ
K. J. HEINZ
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT